



- NOTES:**
- SEPTIC TANK MODEL # C-1500
 - COMPRESSIVE STRENGTH OF THE CONCRETE SHALL BE 32.0 MPA
 - INLET DEVICE SHALL NOT EXTEND MORE THAN 125MM INTO LIQUID LEVEL
 - BURIAL DEPTH = 2.13 METERS
 - WORKING HOLDING CAPACITY = 6145 L (1352 GAL)
- GENERAL NOTE:**
- CHAMFER 30MM @ 45° UNLESS OTHERWISE SPECIFIED TOLERANCES ±2.5MM
 - IF THE TANK IS SET ON UNLEVEL SURFACE, THE BOTTOM OF THE EXCAVATION NEEDS TO BE LEVELLED WITH AGGREGATE IN ORDER TO SUPPORT THE TANK EVENLY.
 - IF THE TANK HAS AT LEAST 12" OF GROUND COVER OVER THE TOP OF IT, THERE IS NO OTHER BALLAST REQUIRED.

<p>152 Brandt Street, Steinbach, MB R5G 0R2 T (204) 326 3445 or 1 800 461 2278 F (204) 326 5915 barkmanconcrete.com</p>	CUSTOMER		PART NUMBER		
	barkman STD PRODUCT		110946		
PROJECT		INITIALS		MM/DD/YYYY	
1500 GALLON CISTERN TANK		DST		06/11/2013	
TITLE		CHECKED BY		DATE	
PRODUCT DETAILS		DATE			
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BARKMAN CONCRETE LTD. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BARKMAN CONCRETE LTD. IS PROHIBITED.		WEIGHT (lbs)	SCALE	PAPER SIZE	SHT NO.
		11,440	N.T.S.	8 1/2 X 11 (A)	1
					REV. #
					0