



**NOTES:**  
 SEPTIC TANK MODEL # H-1000  
 THIS TANK CONFORMS TO CAN/CSA -R368-M10.  
 COMPRESSIVE STRENGTH OF THE CONCRETE SHALL BE 32.0 MPA  
 INLET DEVICE SHALL NOT EXTEND MORE THAN 125MM INTO LIQUID LEVEL.  
 BURIAL DEPTH =2.15 METERS  
 TOTAL WORKING CHAMBER CAPACITY =4641 L (1228 GAL)

**GENERAL NOTE:-**  
 CHAMFER 30MM @ 45° UNLESS OTHERWISE SPECIFIED TOLERANCES ±2.5MM  
 IF THE TANK IS SET ON UNEVEN SURFACE, THE BOTTOM OF THE EXCAVATION  
 NEEDS TO BE LEVELLED WITH AGGREGATE IN ORDER TO SUPPORT THE TANK  
 EVENLY.  
 IF THE TANK HAS AT LEAST 12 OF GROUND COVER OVER THE TOP OF IT,  
 THERE IS NO OTHER BALLAST REQUIRED.

**barkman**<sup>TM</sup>

152 Brandt Street, Steinbach, MB R5G 0R2  
 T (204) 326 3445 or 1 800 461 2278 F (204) 326 5915  
 barkmanconcrete.com

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BARKMAN CONCRETE LTD. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BARKMAN CONCRETE LTD. IS PROHIBITED.

CUSTOMER	<b>barkman STD PRODUCT</b>
PROJECT	<b>1000 GALLON HOLDING TANK</b>
TITLE	<b>PRODUCT DETAILS</b>

PART NUMBER		<b>110917</b>	
	INITIALS	DATE	MM/DD/YYYY
DRAWN BY	DST	DATE	06/11/2013
CHECKED BY		DATE	
WEIGHT (lbs)	SCALE	PAPER SIZE	SHT NO.
11,310	N.T.S.	8 1/2 X 11 (A)	<b>1</b>
			<b>0</b>