



- NOTES:**
- SEPTIC TANK MODEL # P-1400
 - THIS TANK CONFORMS TO CAN/CSA -986-410.
 - COMPRESSIVE STRENGTH OF THE CONCRETE SHALL BE 32.0 MPa.
 - INLET DEVICE SHALL NOT EXTEND MORE THAN 150MM INTO LIQUID LEVEL.
 - BURIAL DEPTH = 2.13 METERS
 - WORKING RETENTION CHAMBER CAPACITY = 4193 L (823 GAL)
 - WORKING PUMP OUT CHAMBER CAPACITY = 1730 L (361 GAL)
 - TOTAL WORKING CHAMBER CAPACITY = 5923 L (1304 GAL)
- GENERAL NOTE:**
- CHAMBER 10MM @ 40' UNLESS OTHERWISE SPECIFIED TOLERANCES ±3.0MM
 - IF THE TANK IS SET ON UNEVEN SURFACE, THE BOTTOM OF THE FOUNDATION NEEDS TO BE LEVELED WITH AGGREGATE IN ORDER TO SUPPORT THE TANK EVENLY.
 - IF THE TANK HAS AT LEAST 12" OF GROUND COVER OVER THE TOP OF IT, THERE IS NO OTHER BALLAST REQUIRED.

barkmanTM

152 Brandt Street, Steinbach, MB R5G 0R2
 T (204) 326 3445 or 1 800 461 2278 F (204) 326 5915
 barkmanconcrete.com

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BARKMAN CONCRETE LTD. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BARKMAN CONCRETE LTD. IS PROHIBITED.

CUSTOMER	barkman STD PRODUCT	
PROJECT	1400 GALLON SEPTIC PUMP TANK	
TITLE	PRODUCT DETAILS	

PART NUMBER		110935	
	INITIALS		MM/DD/YYYY
DRAWN BY	DST	DATE	06/11/2013
CHECKED BY		DATE	
WEIGHT (lbs)	SCALE	PAPER SIZE	SHT NO.
12,365	N.T.S.	8 1/2 X 11 (A)	1
			0