


- NOTES:**
- SEPTIC TANK MODEL # T-750
 - THIS TANK CONFORMS TO CAN/CSA -866-M10.
 - COMPRESSIVE STRENGTH OF THE CONCRETE SHALL BE 32.0 MPA
 - INLET DEVICE SHALL NOT EXTEND MORE THAN 125MM INTO LIQUID LEVEL.
 - BURIAL DEPTH =2.13 METERS
 - WORKING RETENTION CHAMBER CAPACITY =2370 L (628 GAL)
 - WORKING PUMP OUT CHAMBER CAPACITY =485 L (128 GAL)
 - TOTAL WORKING CHAMBER CAPACITY =2855 L (746 GAL)

GENERAL NOTE-

- CHAMFER 30MM @ 45° UNLESS OTHERWISE SPECIFIED TOLERANCES ±2.5MM
- IF THE TANK IS SET ON UNLEVEL SURFACE, THE BOTTOM OF THE EXCAVATION NEEDS TO BE LEVELED WITH AGGREGATE IN ORDER TO SUPPORT THE TANK EVENLY.
- IF THE TANK HAS AT LEAST 12" OF GROUND COVER OVER THE TOP OF IT, THERE IS NO OTHER BALLAST REQUIRED.

 <p>152 Brandt Street, Steinbach, MB R5G 0R2 T (204) 326 3445 or 1 800 461 2278 F (204) 326 5915 barkmanconcrete.com</p>	CUSTOMER		PART NUMBER	
	barkman STD PRODUCT		110901	
PROJECT		INITIALS		MM/DD/YYYY
750 GALLON TRICKLE SEPTIC TANK		DRAWN BY	DST	DATE 06/11/2013
TITLE		CHECKED BY	DATE	
PRODUCT DETAILS		WEIGHT (lbs)	SCALE	PAPER SIZE
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF BARKMAN CONCRETE LTD. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF BARKMAN CONCRETE LTD. IS PROHIBITED.		7,590	N.T.S.	8 1/2 X 11 (A)
		SHT NO.	REV. #	
		1	0	