



PLAN VIEW



- Notes:
1. Concrete Sonotubes to extend a minimum of 1.8m (6.0ft) below grade.
 2. Sonotubes must be placed as wall is constructed.
 3. Geogrid Reinforcement to be cut perpendicular to wall face at centerline of sonotubes.

TYP. CROSS SECTION



Risistone®
retaining wall systems

ArchitexturesXL®
Wall w/ Wood Privacy Fence

<http://www.risistone.com>

©2019 Risk Stone Systems

AXLDET009.DWG