


- Notes:
1. Swale to be dimensioned by Civil Engineer based on site drainage plan.
 2. Swale to slope at min. 2% along the back of wall toward positive outlet.
 3. Swale must be constructed with low permeability soil (100 mm / 4") in thickness to create an effective conduit for water.



Risistone[®]
retaining wall systems

ArchitexturesXL[®]
Swale Detail Typical

AXLDET005.DWG

<http://www.risistone.com>

©2019 Risk Stone Systems