


TYP. SECTION VIEW

Notes:

1. Guiderail post depth to be min. 1.5m (5.0ft) below grade.
2. Guiderail posts must be placed as wall is constructed (not augured through geogrid following construction).
3. Contractor must ensure required compaction around posts, including between back of wall and back of post.
4. Civil Engineer to review required offsets to ensure they are compatible with site layout.



Risistone
retaining wall systems

ArchitexturesXL
Wall w/ Traffic Guard

AXLDET010.DWG

<http://www.risistone.com>

©2019 Risistone Systems