



PLAN VIEW



TYP. CROSS SECTION



- Notes:
1. Concrete Sonotubes to extend a minimum of 1.2m (48") below grade.
  2. Sonotubes must be placed as wall is constructed.
  3. Geogrid Reinforcement to be cut perpendicular to wall face at centerline of sonotubes.



**Risistone®**  
retaining wall systems

**ArchitexturesXL®**

Geogrid Wall w/ Chainlink Fence  
Pedestrian Guardrail (typical)

<http://www.risistone.com>

©2019 Risk Stone Systems

AXLDET007.DWG